


Ø 15.00"

Ø 10.00"

VERIFY BOLD LINE IS 10" LONG



NOTES:

- SUGGESTED BOLT CIRCLE: 12" DIAMETER
 MAXIMUM BOLT CIRCLE: 15" DIAMETER
 MINIMUM BOLT CIRCLE: 10" DIAMETER
- HADCO STRONGLY RECOMMENDS USING LEVELING NUTS TO MOUNT THE POST BASE. IF FOUNDATION IS NOT LEVEL, INCREASE "X" DIMENSION ACCORDINGLY WHEN USING LEVELING NUTS WITH WASHERS.

 X = 3 1/2" MINIMUM WITH LEVELING NUTS
 X = 2 1/2" MINIMUM WITHOUT LEVELING NUTS
- IF USING GROUTING TO CONCEAL GAP BETWEEN BASE AND FOUNDATION, ALLOW FOR WATER DRAINAGE.

	<small>CONFIDENTIAL: This drawing is confidential and proprietary to Signify Holdings and may not be reproduced in whole or in part without the express written consent of Signify Holdings. © 2018 Signify Holdings. All rights reserved.</small>		TITLE: TEMP,CP1619E
	<small>UNLESS OTHERWISE SPECIFIED: *ALL DIMENSIONS ARE IN INCHES. *ALL THREADS ARE UNC-2B OR UNF-2B AFTER COATING. *ALL THREADS ARE TO BE VERIFIED WITH A THREAD GAGE.</small>	DRAWN BY: E. ANDERSON CHECKED BY: B. DORON APPR BY: E. HADDAD	DATE: 6/19/07 DATE: 10/6/09 DATE: 6/19/07
<small>* DO NOT SCALE THIS DRAWING *</small>	EF-04-01-11 Rev.09	SCALE 1:1 SHEET 1 OF 1	PART NO: T01000808