

Certificate No.: SGS/170641

CERTIFICATE OF SUITABILITY

This certificate is issued to confirm that **SGS Systems & Services Certification Pty Ltd** (Electrical Product Certification Services (EPCS) Australia) as accredited by JAS-ANZ in accordance with AS/NZS ISO/IEC 17065 has certified the article described herein to comply with the minimum safety standards for which the Application has been made by :-

PHILIPS LIGHTING B.V.
High Tech Campus 45,
5656 AE Eindhoven
THE NETHERLANDS

DESCRIPTION OF ELECTRICAL EQUIPMENT

Product:	LED Driver (Built-in Type)
Trade Name / Manufacturer:	PHILIPS
Catalogue / Model No(s):	XITANIUM 150W 0.35-0.70A GL Prog sXt; XITANIUM 75W 0.35-0.70A GL Prog sXt
Ratings:	Input: 120-277 V a.c.; 50/60 Hz; Class I; t: 80 °C Output: Constant Current Type; XITANIUM 150W 0.35-0.70A GL Prog sXt:- Max. 300 V d.c., 167 W; XITANIUM 75W 0.35-0.70A GL Prog sXt:- Max. 160 V d.c., 85 W
Standard No.:	AS/NZS IEC 61347.2.13:2013 with AS/NZS 61347.1:2016

REQUIRED MARKING: SGS-170641-E

EXPIRY DATE: 17 August 2022

DATE OF CERTIFICATION: 18 August 2017

JAS-ANZ



www.jas-anz.org/register



For and On Behalf of
SGS Systems & Services Certification Pty Ltd



"This document is issued by the Company under its General Conditions of Service accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law."