

# IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product	Electronic driver for LED modules
Name and address of the applicant	Signify Netherlands B.V. High Tech Campus 48 5656 AE Eindhoven The Netherlands
Name and address of the manufacturer	Signify Netherlands B.V. High Tech Campus 48 5656 AE Eindhoven The Netherlands
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 <div style="border: 1px solid black; height: 60px; width: 240px; margin-top: 5px;"></div>
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	U <sub>in</sub> : 120...277 V, f <sub>n</sub> : 50/60 Hz, I <sub>in</sub> : 0.96...0.42 A U <sub>out</sub> : 72...143 V, U-OUT = 200 Vdc(max), t <sub>c</sub> : 80 °C I <sub>out</sub> : 100...700 mA, P <sub>out</sub> : 100 W, PF: 0.98...0.93
Trademark (if any)	PHILIPS
Customer's Testing Facility (CTF) Stage used	CTF Stage 3
Model / Type Ref.	XITANIUM 100W 0.70A Prog+ GL-Z sXt
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2 This certificate replaces certificate no. NL-38569, dated on 2015-11-20 due to update standards
A sample of the product was tested and found to be in conformity with	IEC 61347-1:2015, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016, IEC 62384:2006, IEC 62384:2006/AMD1:2009 National differences: EU Group Differences
As shown in the Test Report Ref. No. which forms part of this Certificate	2241322.52 and 2241322.53

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2019-11-21

Signature: Anouschka Slingerland



page 1 of 1