

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Electronic controlgear for LED modules

Name and address of the applicant

Signify Netherlands B.V.
High Tech Campus 48, 5656 AE Eindhoven
Netherlands

Name and address of the manufacturer

Signify Netherlands B.V.
High Tech Campus 48, 5656 AE Eindhoven
Netherlands

Name and address of the factory

When more than one factory, please report on page 2☒ Additional information on page 2

Ratings and principal characteristics

Product dataRatings: Uin: 220-240 Vac; Iin: 0,8-0,67 Aac;
Uin: 186-250 Vdc; Iin: 0,54 Adc max;
Pin: 165 W; fn: 50/60 Hz; DC; PF: 0.95;
Output Voltage(range): 100-214 Vdc;
Uout: 320 Vdc (Max. open circuit);
Iout: 700 mA dc; Pout: 150 W;
tc: 85 °C; ta: -40...+55 °C; built-in

Trademark / Brand (if any)

PHILIPS
PHILIPS

Customer's Testing Facility (CTF) Stage used

CTF Stage 3

Model / Type Ref.

Xitanium 150W 0.70A 1-10V 230V S240 sXt

Additional information (if necessary may also be reported on page 2)

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016 and IEC 62384:2020

National differences:
EU Group Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

6155072.50 and 6155072.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 25 October 2023

Signature: K. Lin



Ref. Certif. No.

NL-101116

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional factory

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 25 October 2023

K. Lin

Signature: K. Lin

