Ref. Certif. No.

NL-125456

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Electronic Controlgear for LED modules
Name and address of the applicant	Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, Netherlands
Name and address of the manufacturer	Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, Netherlands
Name and address of the factory	
When more than one factory	☐ Additional information on page 2
Ratings and principal characteristics	**Product data – type 9290014207** Ratings: Un: 220-240 Vac; In: 0,023 Aac; fn: 50/60 Hz; Pn: 5,25 W; PF: 0,95 Iout: 0,1 Adc; Pout: 4 W; output voltage: 29-40 Vdc; Uout: 60 Vdc; ta: -20…+50 °C; tc: 80 °C; independent; SELV **Product data – type 9290014208** Ratings: Un: 220-240 Vac; In: 0,033 Aac; fn: 50/60 Hz; Pn: 7,4 W; PF: 0,95 Iout: 0,15 Adc; Pout: 6 W; output voltage: 29-40 Vdc; Uout: 60 Vdc; ta: -20…+50 °C; tc: 80 °C; independent; SELV **Product data – type 9290014209** Ratings: Un: 220-240 Vac; In: 0,04 Aac; fn: 50/60 Hz; Pn: 9 W; PF: 0,95 Iout: 0,35 Adc; Pout: 7 W; output voltage: 8-20 Vdc; Uout: 60 Vdc; ta: -20…+50 °C; tc: 80 °C; independent; SELV **Product data – type 9290014210** Ratings: Un: 220-240 Vac; In: 0,044 Aac; fn: 50/60 Hz; Pn: 9,8 W; PF: 0,95 Iout: 0,2 Adc; Pout: 8 W; output voltage: 29-40 Vdc; Uout: 60 Vdc; ta: -20…+50 °C; tc: 80 °C; independent; SELV **Product data – type 9290014211** Ratings: Un: 220-240 Vac; In: 0,052 Aac; fn: 50/60 Hz; Pn: 12 W; PF: 0,95 Iout: 0,25 Adc; Pout: 10 W; output voltage: 29-40 Vdc; Uout: 60 Vdc; ta: -20…+50 °C; tc: 80 °C; independent; SELV **Product data – type 9290014212** Ratings: Un: 220-240 Vac; In: 0,056 Aac; fn: 50/60 Hz; Pn: 12,8 W; PF: 0,95 Iout: 0,5 Adc; Pout: 10 W; output voltage: 8-20 Vdc; Uout: 60 Vdc; ta: -20…+50 °C; tc: 80 °C; independent; SELV **Product data – type 9290014213** Ratings: Un: 220-240 Vac; In: 0,072 Aac; fn: 50/60 Hz; Pn: 16 W; PF: 0,95 Iout: 0,35 Adc; Pout: 14 W; output voltage: 29-40 Vdc; Uout: 60 Vdc; ta: -20…+50 °C; tc: 80 °C; independent; SELV **Product data – type 9290014214**

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-04-30

Signature: Kreny Lin

Ref. Certif. No.

NL-125456

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

	Ratings: Un: 220-240 Vac; In: 0,08 Aac; fn: 50/60 Hz; Pn: 18 W; PF: 0,95 Iout: 0,75 Adc; Pout: 15 W; output voltage: 8-20 Vdc; Uout: 60 Vdc; ta: -20…+50 °C; tc: 85 °C; independent; SELV
Trademark / Brand (if any)	PHILIPS, SIGNIFY, XITANIUM or ADVANCE
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	9290014207, 9290014208, 9290014209, 9290014210, 9290014211, 9290014212, 9290014213 and 9290014214
Additional information	☐ Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016 and IEC 62384:2020 National differences: EU Group Differences
As shown in the Test Report Ref. No. which forms part of this Certificate	6266118.50 and 6266118.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-04-30

Signature: Kreny Lin