Ref. Certif. No.

NL-126385

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Electronic controlgear for LED modules
Name and address of the applicant	Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, Netherlands
Name and address of the manufacturer	Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, Netherlands
Name and address of the factory	
When more than one factory	☒ Additional information on page 3
Ratings and principal characteristics	**Product data** Ratings: XITANIUM 20W/m 0.15-0.5A 52V 230V Un: 220-240 Vac; 186-250 Vdc; fn: 50/60 Hz; DC; In: 0,12 Aac, 0,13-0,09 Adc; PF: 0,9C; Pn: 24W; Irated: 0,5 Adc; Prated: 20 W; Uout: 60 Vdc max; tc: 80 °C; ta: -20…+50 °C; Built-in; Independent (with SR caps) XITANIUM 36W/m 0.3-1.05A 52V 230V Un: 220-240 Vac; 186-250 Vdc; fn: 50/60 Hz; DC; In: 0,2 Aac, 0,23-0,16 Adc; PF: 0,9C; Pn: 42W; Irated: 1,05 Adc; Prated: 36 W; Uout: 60 Vdc max; tc: 80 °C; ta: -20…+50 °C; Built-in; Independent (with SR caps) XITANIUM 43W/m 0.7-1.2A 52V 230V Un: 220-240 Vac; 186-250 Vdc; fn: 50/60 Hz; DC; In: 0,23 Aac, 0,27-0,19 Adc; PF: 0,9C; Pn: 50W; Irated: 1,2 Adc; Prated: 43 W; Uout: 60 Vdc max; tc: 90 °C; ta: -20…+45 °C; Built-in; Independent (with SR caps)
Trademark / Brand (if any)	PHILIPS, SIGNIFY, XITANIUM or ADVANCE
Customer's Testing Facility (CTF) Stage used	CTF Stage 3
Model / Type Ref.	XITANIUM 20W/m 0.15-0.5A 52V 230V, XITANIUM 36W/m 0.3-1.05A 52V 230V and XITANIUM 43W/m 0.7-1.2A 52V 230V
Additional information	☐ Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016 and IEC 62384:2020

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-06-03

Signature: Carol Jwo

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

National differences:
EU Group Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

6271245.50 and 6271245.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-06-03

Signature: Carol Jwo

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional factory

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-06-03

Signature: Carol Jwo