

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Electronic controlgear for LED modules
Name and address of the applicant	Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, Netherlands
Name and address of the manufacturer	Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, Netherlands
Name and address of the factory	
<i>When more than one factory</i>	<input checked="" type="checkbox"/> Additional information on page 3
Ratings and principal characteristics	Product data – type Xitanium 35W 0.08-0.35A 150V 16 230V Ratings: Un: 220-240 V; fn: 50/60 Hz; DC; In: 0,17 A; Pn: 39 W; PF: 0,9C; Irated: 0,08-0,35 A; Prated: 35 W; Uoutput: 50-150 Vdc, Uout: 250 Vdc max; tc: 75 °C; ta: -25...+50 °C; Built-in Product data – type Xitanium 60W 0.08-0.35A 220V 16 230V Ratings: Un: 220-240 V; fn: 50/60 Hz; DC; In: 0,3 A; Pn: 66 W; PF: 0,9C; Irated: 0,08-0,35 A; Prated: 60 W; Uoutput: 50-220 Vdc, Uout: 250 Vdc max; tc: 75 °C; ta: -25...+50 °C; Built-in Product data – type Xitanium 60W 0.08-0.35A 300V 16 230V Ratings: Un: 220-240 V; fn: 50/60 Hz; DC; In: 0,3 A; Pn: 66 W; PF: 0,9C; Irated: 0,08-0,35 A; Prated: 60 W; Uoutput: 100-300 Vdc, Uout: 330 Vdc max; tc: 75 °C; ta: -25...+50 °C; Built-in
Trademark / Brand (if any)	PHILIPS or SIGNIFY
Customer's Testing Facility (CTF) Stage used	CTF Stage 3
Model / Type Ref.	Xitanium 35W 0.08-0.35A 150V 16 230V, Xitanium 60W 0.08-0.35A 220V 16 230V and Xitanium 60W 0.08-0.35A 300V 16 230V
Additional information	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016 and IEC 62384:2020 National differences: EU Group Differences

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2025-07-11

Signature: Kreny Lin



IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Comments:

This CB test certificate replaces CB test certificate NL-101205.

This certificate replaces NL-101205 dated on 2023-10-23 due to technical modifications.

6231443.50 and 6231443.51

As shown in the Test Report Ref. No.
which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands



Date: 2025-07-11

Signature: Kreny Lin



Ref. Certif. No.

NL-101205/M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional factory

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands



Date: 2025-07-11

Signature: Kreny Lin