


IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

| | |
|---------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Product | Electronic controlgear for LED modules |
| Name and address of the applicant | Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, Netherlands |
| Name and address of the manufacturer | Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, Netherlands |
| Name and address of the factory | |
| <i>When more than one factory</i> | <input checked="" type="checkbox"/> Additional information on page 2 |
| Ratings and principal characteristics | Product data – type Xitanium 36W 0.3-1.05A 54V S 230V Ratings: Un: 220-240 V ac/dc; In: 0,2 A ac/dc; Pn: 41 W; fn: 50/60 Hz, DC; PF: 0.9C; Output Voltage(range): 27-54 Vdc, Uout: 60V dc max; Iout: 0,3-1,05 A dc; Pout: 36 W; tc: 75 °C; ta: -25...+50 °C; Built-in; SELV Product data – type Xitanium 65W 0.5-1.4A 54V S 230V Ratings: Un: 220-240 V ac/dc; In: 0,32 A ac/dc; Pn: 74 W; fn: 50/60 Hz, DC; PF: 0.9C; Output Voltage(range): 27-54 Vdc, Uout: 60V dc max; Iout: 0,5-1,4 A dc; Pout: 65 W; tc: 75 °C; ta: -25...+50 °C; Built-in; SELV |
| Trademark / Brand (if any) | PHILIPS or SIGNIFY |
| Customer's Testing Facility (CTF) Stage used | CTF Stage 3 |
| Model / Type Ref. | Xitanium 36W 0.3-1.05A 54V S 230V and Xitanium 65W 0.5-1.4A 54V S 230V |
| Additional information | <input type="checkbox"/> Additional information on page 2 |
| A sample of the product was tested and found to be in conformity with | IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016 and IEC 62384:2020 National differences: EU Group Differences |
| As shown in the Test Report Ref. No. which forms part of this Certificate | 6231441.50 and 6231441.51 |

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2025-07-04

Signature: Miranda Zhou



Ref. Certif. No.

NL-117964

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional factory

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands



Date: 2025-07-04

Signature: Miranda Zhou