



# Certificate of Conformity/Approval

**Certificate No.:** **SAA-200795-EA**

<b>Certificate Holder:</b>	Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, Netherlands
<b>Regulatory Definition:</b>	Power Supply or Charger
<b>Product Description:</b>	Battery-supplied LED controlgear for emergency lighting (Independent Constant current SELV, Self-contained)
<b>Trade Name/s:</b>	PHILIPS
<b>Model No.:</b>	TrustSight DALI 15-55V LFP
<b>Rating/Marking/s:</b>	Input: 220-240Vac 50/60Hz 30mA 3-6W Output: 60Vdc 55-340mA 3-5W 15-55V LFP Battery(1S3P, 2S2P or 3S2P) 1.5Ah ta:-20°C to +55°C tc: 75°C, EL-T
<b>Standard/s:</b>	AS 61347.2.7:2019 AS 61347.2.13:2018 AS/NZS 61347.1:2016 Inc A1
<b>Condition/s:</b>	Nil
<b>Approval Marks:</b>	RCM (In accordance with AS/NZS 4417 and EESS requirements) and SAA-200795-EA (In accordance with NSW legislative requirements)
<b>Initial Issue Date:</b>	8 July 2020
<b>Expiry Date:</b>	8 July 2025



---

For and on Behalf of  
**SAA Approvals Pty Ltd**

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein. For SAA Contact Details and Certificate verification, go to: [www.saaapprovals.com.au](http://www.saaapprovals.com.au)



Issued: 02-03-21 200795/1a  
Reissued, updated



# Certificate of Conformity/Approval

---

## \*Addendum\*

**Certificate No.:** **SAA-200795-EA**

**Date of Issue:** **2 March 2021**

**Regulatory Definition:** Power Supply or Charger  
**Product Description:** Battery-supplied LED controlgear for emergency lighting  
(Independent Constant current SELV, Self-contained)

<b>Additional Models</b>	<b>Trade Name</b>	<b>Rating/Marking</b>
TrustSight DALI 15-55V NiMH	PHILIPS	Input: 220-240Vac 50/60Hz 30mA 3-5W Output: 60Vdc 55-340mA 3-5W 15-55V NiMH Battery (3, 4 or 5 cell) 4Ah ta:-20°C to +55°C tc:75°C, EL-T



For and on Behalf of  
**SAA Approvals Pty Ltd**

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein. For SAA Contact Details and Certificate verification, go to: [www.saaapprovals.com.au](http://www.saaapprovals.com.au)



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 02-03-21 200795/2a  
Reissued, updated