

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Electronic controlgear for LED modules

Name and address of the applicant

Signify Netherlands B.V.
High Tech Campus 48, 5656 AE Eindhoven
Netherlands

Name and address of the manufacturer

Signify Netherlands B.V.
High Tech Campus 48, 5656 AE Eindhoven
Netherlands

Name and address of the factory

When more than one factory, please report on page 2☒ Additional information on page 2

Ratings and principal characteristics

Product data

Ratings: Un: 220...240 V In: 0,27 A Pn: 60 W
fn: 50-60 Hz; DC Un: 186...250 Vdc In: 0,32 Adc
Iout: 1,5 A Uout: 60 Vmax Pout.: 50 W
PF: 0,9 C ta: -20...+55 °C tc max: 90 °C

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

CTF Stage 3

Model / Type Ref.

Xitanium 50W WH 0.7-1.5A 54V TD/Is 230V,
Xitanium 50W WH 0.7-1.5A 54V TD/Is CL and
Xitanium 50W WH 0.7-1.5A 54V TD S CL

Additional information (if necessary may also be reported on page 2)

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014,
IEC 61347-2-13:2014/AMD1:2016, IEC 62384:2020 and IEC 60598-1:2020

National differences:

EU Group Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

6155113.50 and 6155113.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 10 January 2024


Signature: C Chen 



Ref. Certif. No.

NL-103221

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional factory

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 10 January 2024


Signature: C Chen

