

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product Battery supplied LED controlgear for emergency lighting (self-contained)

Name and address of the applicant Signify Netherlands B.V.  
High Tech Campus 48, 5656 AE Eindhoven,  
The Netherlands

Name and address of the manufacturer Signify Netherlands B.V.  
High Tech Campus 48, 5656 AE Eindhoven,  
The Netherlands

Name and address of the factory ☐ Additional information on page 2

Note: When more than one factory, please report on page 2

Ratings and principal characteristics TrustSight PRO 15-55V NiMH  
TrustSight DALI 15-55V NiMH  
TrustSight BASIC 15-55V NiMH  
TrustSight PRO 15-55V NiMH IDT  
TrustSight DALI 15-55V NiMH IDT  
Un: 220...240 V; In: 30 mA; Pn: 3-5 W; fn: 50/60 Hz; PF: 0,70C;  
U-OUT: 60 V; P-OUT: 3-5 W; I-OUT: 55-340 mA;  
ta: -20...+55 °C; tc: +75 °C; SELV

TrustSight PRO 15-55V LFP  
TrustSight DALI 15-55V LFP  
TrustSight BASIC 15-55V LFP  
Un: 220...240 V; In: 30 mA; Pn: 3-6 W; fn: 50/60 Hz; PF: 0,70C;  
U-OUT: 60 V; P-OUT: 3-5 W; I-OUT: 55-340 mA;  
ta: -20...+55 °C; tc: +75 °C; SELV

Trademark (if any) PHILIPS

Customer's Testing Facility (CTF) Stage used CTF Stage 3

Model / Type Ref. TrustSight PRO 15-55V NiMH  
TrustSight PRO 15-55V LFP  
TrustSight DALI 15-55V NiMH  
TrustSight DALI 15-55V LFP  
TrustSight BASIC 15-55V NiMH  
TrustSight BASIC 15-55V LFP  
TrustSight PRO 15-55V NiMH IDT  
TrustSight DALI 15-55V NiMH IDT

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands



IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

☐ Additional information on page 2

IEC 60598-1:2014, IEC 60598-1:2014/AMD1:2017, IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016, IEC 61347-2-7:2011, IEC 61347-2-7:2011/AMD1:2017, IEC 62384:2006, IEC 62384:2006/AMD1:2009

National differences:

EU Group Differences

6094105.50 to 6094105.52

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2021-01-12

Signature: Kate Xu



page 2 of 2