

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
 (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product	Battery supplied LED controlgear for emergency lighting (self-contained)
Name and address of the applicant	Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, The Netherlands
Name and address of the manufacturer	Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, The Netherlands
Name and address of the factory	<input type="checkbox"/> Additional information on page 2
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	TrustSight PRO 45-300V NiMH TrustSight DALI 45-300V NiMH TrustSight BASIC 45-300V NiMH TrustSight PRO 45-300V NiMH IDT TrustSight DALI 45-300V NiMH IDT Un: 220...240 V; In: 30 mA; Pn: 3-5 W; fn: 50/60 Hz; PF: 0,70C U-OUT: 330 V; P-OUT: 3-5 W; I-OUT: 10-120 mA; ta: -20...+55 °C; tc: + 75 °C; isolated
	TrustSight PRO 45-300V LFP TrustSight DALI 45-300V LFP TrustSight BASIC 45-300V LFP Un: 220...240 V; In: 30 mA; Pn: 3-6 W; fn: 50/60 Hz; PF: 0,70C U-OUT: 330 V; P-OUT: 3-5 W; I-OUT: 10-120 mA; ta: -20...+55 °C; tc: +75 °C; isolated
Trademark (if any)	PHILIPS
Customer's Testing Facility (CTF) Stage used	CTF Stage 3
Model / Type Ref.	TrustSight PRO 45-300V NiMH TrustSight PRO 45-300V LFP TrustSight DALI 45-300V NiMH TrustSight DALI 45-300V LFP TrustSight BASIC 45-300V NiMH TrustSight BASIC 45-300V LFP TrustSight PRO 45-300V NiMH IDT TrustSight DALI 45-300V NiMH IDT

This CB Test Certificate is issued by the National Certification Body

 DEKRA Certification B.V.  
 Meander 1051, NL-6825 MJ Arnhem, Netherlands


  


IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

Additional information (if necessary may also be reported on page 2)

Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016, IEC 61347-2-7:2011, IEC 61347-2-7:2011/AMD1:2017, IEC 62384:2006, IEC 62384:2006/AMD1:2009

**National differences:**

EU Group Differences

6094109.50 to 6094109.52

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands

