



# Certificate of Suitability

**Certificate No.:** **SAA200796**

**Certificate Holder:** Signify Netherlands B.V.  
High Tech Campus 48,  
5656 AE Eindhoven,  
Netherlands

**Regulatory Definition:** Non-Prescribed  
**Product Description:** Battery-supplied LED controlgear for emergency lighting  
(Built-in, self-contained, Constant current,  
For Commercial use)

**Trade Name/s:** PHILIPS  
**Model No.:** TrustSight DALI 15-55V LFP  
**Rating/Marking/s:** Un: 220-240Vac, In: 30mA,  
Pn: 3-6W, fn: 50/60Hz, PF: 0.70C  
Pout: 3-5W, Iout: 55-340mA, Uout: 60V  
ta: -20°C to +55°C tc: 75°C

**Standard/s:** AS 61347.2.7:2019  
AS 61347.2.13:2018

**Condition/s:** AS/NZS 61347.1:2016 Inc A1  
All models approved under this Certificate  
must comply with the Standard requirements  
of the end product when installed.

**Approval Marks:** RCM and SAA200796

**Initial Issue Date:** 8 July 2020  
**Expiry Date:** 8 July 2025

For and on Behalf of  
**SAA Approvals Pty Ltd**

SAA Approvals Pty Ltd as accredited by JAS-ANZ under  
ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety  
Act 2002 and Electrical Safety Regulations 2013* certifies in  
accordance with the SAA Approvals Electrical Product Safety  
Certification Scheme that the product nominated in this certificate  
complies with standard/s listed.

When using the RCM the requirements of all relevant parts of  
AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

[www.saaapprovals.com.au](http://www.saaapprovals.com.au)



Issued: 02-03-21 200796/1a  
Reissued, updated



# Certificate of Suitability

## \*Addendum\*

**Certificate No.:** SAA200796

**Date of Issue:** 2 March 2021

**Regulatory Definition:** Non-Prescribed

**Product Description:** Battery-supplied LED controlgear for emergency lighting  
(Built-in, self-contained, Constant current,  
For Commercial use)

Additional Models	Trade Name	Rating/Marking
TrustSight DALI 15-55V NiMH	PHILIPS	Un: 220-240Vac, In: 30mA, Pn: 3-5W, fn: 50/60Hz, PF: 0.70C Pout: 3-5W, Iout:55-340mA, Uout: 60V ta: -30°C to +55°C tc: 75°C
TrustSight DALI 45-300V LFP	PHILIPS	Un: 220-240Vac, In: 30mA, Pn: 3-6W, fn: 50/60Hz, PF: 0.70C Pout: 3-5W, Iout:10-120mA, Uout: 330V ta: -30°C to +55°C tc: 75°C
TrustSight DALI 45-300V NiMH	PHILIPS	Un: 220-240Vac, In: 30mA, Pn: 3-5W, fn: 50/60Hz, PF: 0.70C Pout: 3-5W, Iout:10-120mA, Uout: 300V ta: -30°C to +55°C tc: 75°C

For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

[www.saaapprovals.com.au](http://www.saaapprovals.com.au)



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 02-03-21 200796/2a  
Reissued, updated