



Ref. Certif. No.

NL-62274/M2

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

LED driver

Name and address of the applicant

Signify Netherlands B.V.  
High Tech Campus 48, 5656 AE Eindhoven,  
Netherlands

Name and address of the manufacturer

Signify Netherlands B.V.  
High Tech Campus 48, 5656 AE Eindhoven,  
Netherlands

Name and address of the factory

*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

Xitanium 75W 0.7-2.0A 54V 230V  
Un: 220-240Vac; In: 0,38A; fn: 50/60Hz;  
Un: 186-250Vdc; In: 0,46-0,34Adc; Pn: 85W;  
Output voltage: 27-54Vdc, Uout: 60Vdc; Iout: 0,7-2,0A; Pout: 75W;  
ta: -20...+50°C; tc: 75°C; PF: 0,9C; SELV; built-in; ELXitanium 36W 0.3-1.0A 54V 230V  
Un: 220-240Vac; In: 0,2A; fn: 50/60Hz;  
Un: 186-250Vdc; In: 0,24-0,17Adc; Pn: 41W;  
Output voltage: 27-54Vdc, Uout: 60Vdc; Iout: 0,3-1,0A; Pout: 36W;  
ta: -20...+50°C; tc: 75°C; PF: 0,9C; SELV; built-in; EL

Trademark / Brand (if any)

PHILIPS

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Xitanium 75W 0.7-2.0A 54V 230V  
Xitanium 36W 0.3-1.0A 54V 230V

Additional information (if necessary may also be reported on page 2)

This certificate replaces NL-62274/M1 dated on 2021-11-08 due to technical modifications.

 Additional information on page 2

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016, IEC 62384:2020

National differences:

EU Group Differences

6147815.50 and 6147815.51

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051  
Arnhem, 6825 MJ  
Netherlands

Date: 2023-02-16

Signature: Kate Xu