Ref. Certif. No.

NL-126826

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Electronic controlgear for LED modules
Name and address of the applicant	Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, Netherlands
Name and address of the manufacturer	Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, Netherlands
Name and address of the factory	
When more than one factory	☒ Additional information on page 3
Ratings and principal characteristics	**Product data** Ratings: Xitanium 90W 0.25-0.7A 220V TD21 230V Xitanium 90W 0.25-0.7A 220V TD21 S 230V Uin: 220 - 240 Vac Iin: 0.44 Aac Pin: 97 W Uin: 186 - 250 Vdc Iin: 0.52 - 0.39 Adc PF: 0.9C fn: 50/60 Hz; DC Uoutput: 50 - 220 Vdc Irated: 0.25 - 0.70 Adc Uout = 250 V max Prated: 90 W tc: 75 °C ta: -25...+50 °C Xitanium 90W 0.15-0.5A 300V TD21 S 230V Xitanium 90W 0.15-0.5A 300V TD21CL 230V Uin: 220 - 240 Vac Iin: 0.44 Aac Pin: 97 W Uin: 186 - 250 Vdc Iin: 0.52 - 0.39 Adc PF: 0.9C fn: 50/60 Hz; DC Uoutput: 100 - 300 Vdc Irated: 0.15 - 0.50 Adc Uout = 330 V max Prated: 90 W tc: 75 °C ta: -25...+50 °C
Trademark / Brand (if any)	PHILIPS, SIGNIFY, XITANIUM or ADVANCE
Customer's Testing Facility (CTF) Stage used	CTF Stage 3
Model / Type Ref.	Xitanium 90W 0.15-0.5A 300V TD21CL 230V, Xitanium 90W 0.15-0.5A 300V TD21 S 230V, Xitanium 90W 0.25-0.7A 220V TD21 230V and Xitanium 90W 0.25-0.7A 220V TD21 S 230V
Additional information	☐ Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016 and IEC 62384:2020

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-06-15

Signature: Carol Jwo

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

National differences:
EU Group Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

6271322.50 and 6271322.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-06-15

Signature: Carol Jwo

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional factory

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-06-15

Signature: Carol Jwo