Ref. Certif. No.

NL-126316

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Electronic Controlgear for LED modules
Name and address of the applicant	Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, Netherlands
Name and address of the manufacturer	Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, Netherlands
Name and address of the factory	
When more than one factory	☒ Additional information on page 3
Ratings and principal characteristics	**Product data** Ratings: Xi LP 22W 0.2-0.7A S1 230V C123 sXt: Un: 220-240V; fn: 50/60 Hz; Iin: 0,12-0,11A; Pin: 26W; PF: 0,95; Uoutput: 16-48Vdc, Uout 70 Vmax; Irated: 200-700 mA; Prated: 22W; ta: -40..+55°C; tc: 85 °C; SELV Xi LP 22W 0.3-1.0A S1 230V C123 sXt: Un: 220-240V; fn: 50/60 Hz; Iin: 0,12-0,11A; Pin: 26W; PF: 0,95; Uoutput: 8-32Vdc, Uout 50 Vmax; Irated: 300-1050mA; Prated: 22W; ta: -40..+55°C; tc: 85 °C; SELV Xi LP 40W 0.2-0.7A S1 230V C123 sXt: Un: 220-240V; fn: 50/60 Hz; Iin: 0,21-0,19A; Pin: 46W; PF: 0,95; Uoutput: 25-77Vdc, Uout 100 Vmax; Irated: 200-700mA; Prated: 40W; ta: -40..+55°C; tc: 85 °C; SELV Xi LP 40W 0.3-1.0A S1 230V C123 sXt: Un: 220-240V; fn: 50/60 Hz; Iin: 0,21-0,19A; Pin: 46W; PF: 0,95; Uoutput: 20-54Vdc, Uout 60 Vmax; Irated: 300-1050mA; Prated: 40W; ta: -40..+55°C; tc: 85 °C; SELV
Trademark / Brand (if any)	PHILIPS, SIGNIFY, XITANIUM or ADVANCE
Customer's Testing Facility (CTF) Stage used	CTF Stage 3
Model / Type Ref.	Xi LP 22W 0.2-0.7A S1 230V C123 sXt, Xi LP 22W 0.3-1.0A S1 230V C123 sXt, Xi LP 40W 0.2-0.7A S1 230V C123 sXt and Xi LP 40W 0.3-1.0A S1 230V C123 sXt
Additional information	☐ Additional information on page 2

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-06-01

Signature: Miranda Zhou

Ref. Certif. No.

NL-126316

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

A sample of the product was tested and found to be in conformity with	IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016 and IEC 62384:2020 National differences: EU Group Differences
As shown in the Test Report Ref. No. which forms part of this Certificate	6271099.50 and 6271099.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-06-01

Signature: Miranda Zhou

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional factory

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-06-01

Signature: Miranda Zhou