

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Electronic controlgear for LED modules

Name and address of the applicant

Signify Netherlands B.V.
High Tech Campus 48, 5656 AE Eindhoven
Netherlands

Name and address of the manufacturer

Signify Netherlands B.V.
High Tech Campus 48, 5656 AE Eindhoven
Netherlands

Name and address of the factory

When more than one factory, please report on page 2☐ Additional information on page 2

Ratings and principal characteristics

Product dataRatings: Input: 220-240 V 50/60 Hz 0,11-0,2 A, 186-250 V 0 Hz 0,13-0,23 A
Output: 0,15-1,05 A, 20-36 W, UOUT= 60 Vdc
For specific electrical rating refer to Test Report

Trademark / Brand (if any)

PHILIPS

Customer's Testing Facility (CTF) Stage used

CTF Stage 3

Model / Type Ref.

XITANIUM (series) For specific Model/Type refer to Test Report

Additional information (if necessary may also be reported on page 2)

☒ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016 and IEC 62384:2020

National differences:

AU, EU Group Differences, NZ

As shown in the Test Report Ref. No. which forms part of this Certificate

3509080.370 and 3509080.371

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Signature: A.C. Slingerland



Date: 8 November 2023



Ref. Certif. No.

NL-101486

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

[Additional information](#)

The CB Certificate updates the CB no. NL-62243 dated 2019-11-19, refer to Test Report for details

[This CB Test Certificate is issued by the National Certification Body](#)

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

[Date:](#) 8 November 2023

[Signature:](#) A.C. Slingerland

