Ref. Certif. No.

NL-126616

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Electronic controlgear for LED modules
Name and address of the applicant	Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, Netherlands
Name and address of the manufacturer	Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, Netherlands
Name and address of the factory	
When more than one factory	☒ Additional information on page 3
Ratings and principal characteristics	**Product data** Ratings: Xitanium 35W 0.08-0.35A 220V S16 230V: Un: 220-240 V; In: 0,17 A; Pn: 39 W; fn: 50/60 Hz; DC; PF: 0,9C; Uoutput: 50-220 Vdc; Uout: 250 Vmax; Prated: 35 W; Irated: 0,08-0,35 Adc; ta: -25…+50°C; tc: 75°C; Built-in Xitanium 60W 0.08-0.35A 300V S16 230V: Un: 220-240 V; In: 0,3 A; Pn: 66 W; fn: 50/60 Hz; DC; PF: 0,9C; Uoutput: 100-300 Vdc; Uout: 330 Vmax; Prated: 60 W; Irated: 0,08-0,35 Adc; ta: -25…+50°C; tc: 75°C; Built-in Xitanium 60W 0.15-0.5A 220V S16 230V: Un: 220-240 V; In: 0,3 A; Pn: 66 W; fn: 50/60 Hz; DC; PF: 0,9C; Uoutput: 50-220 Vdc; Uout: 250 Vmax; Prated: 60 W; Irated: 0,15-0,5 Adc; ta: -25…+50°C; tc: 75°C; Built-in
Trademark / Brand (if any)	PHILIPS, SIGNIFY, XITANIUM or ADVANCE
Customer's Testing Facility (CTF) Stage used	CTF Stage 3
Model / Type Ref.	Xitanium 35W 0.08-0.35A 220V S16 230V, Xitanium 60W 0.08-0.35A 300V S16 230V and Xitanium 60W 0.15-0.5A 220V S16 230V
Additional information	☐ Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016 and IEC 62384:2020 National differences: EU Group Differences

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-06-09

Signature: May Liu

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

As shown in the Test Report Ref. No. which forms part of this Certificate	6271303.50 and 6271303.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-06-09

Signature: May Liu

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional factory

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-06-09

Signature: May Liu