Ref. Certif. No.

NL-126736

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Electronic Controlgear for LED modules
Name and address of the applicant	Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, Netherlands
Name and address of the manufacturer	Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, Netherlands
Name and address of the factory	
When more than one factory	☐ Additional information on page 2
Ratings and principal characteristics	**Product data** Ratings: Xitanium 20W/a 0.15-0.5A 42V 3CW 230V: Xitanium 20W/a 0.15-0.5A 42V 3CB 230V: Xitanium 20W/a 0.15-0.5A 42V 3CG 230V: Un: 220-240 V~; fn: 50/60 Hz; In: 0,12 A; Pn: 25 W; PF: 0,9C; Irated: 0,15-0,5 A; Prated: 20 W; Uoutput: 10-42 Vdc, Uout: 60 Vdc max; tc: 85 °C; ta: -20…+35 °C; SELV; Built-in Xitanium 42W/a 0.3-1.05A 42V 3CW 230V: Xitanium 42W/a 0.3-1.05A 42V 3CB 230V: Xitanium 42W/a 0.3-1.05A 42V 3CG 230V: Un: 220-240 V~; fn: 50/60 Hz; In: 0,25 A; Pn: 50 W; PF: 0,9C; Irated: 0,3-1,05 A; Prated: 42 W; Uoutput: 10-42 Vdc, Uout: 60 Vdc max; tc: 85 °C; ta: -20…+35 °C; SELV; Built-in
Trademark / Brand (if any)	PHILIPS, SIGNIFY, ADVANCE or XITANIUM
Customer's Testing Facility (CTF) Stage used	CTF Stage 3
Model / Type Ref.	Xitanium 20W/a 0.15-0.5A 42V 3CB 230V, Xitanium 20W/a 0.15-0.5A 42V 3CG 230V, Xitanium 20W/a 0.15-0.5A 42V 3CW 230V, Xitanium 42W/a 0.3-1.05A 42V 3CB 230V, Xitanium 42W/a 0.3-1.05A 42V 3CG 230V and Xitanium 42W/a 0.3-1.05A 42V 3CW 230V
Additional information	☐ Additional information on page 2

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-06-11

Signature: May Liu

Ref. Certif. No.

NL-126736

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

A sample of the product was tested and found to be in conformity with	IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016 and IEC 62384:2020 National differences: AU, EU Group Differences, NZ
As shown in the Test Report Ref. No. which forms part of this Certificate	6271329.50(A-B) and 6271329.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-06-11

Signature: May Liu