

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

| | |
|--|--|
| Product | LED driver |
| Name and address of the applicant | Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, The Netherlands |
| Name and address of the manufacturer | Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, The Netherlands |
| Name and address of the factory | <input type="checkbox"/> Additional information on page 2 |
| <i>Note: When more than one factory, please report on page 2</i> | |
| Ratings and principal characteristics | <p>CertaDrive 19W 200-350mA 54V DS 230V Uin: 220-240V; Freq: 50/60Hz; Iin: 0,09A; Pin: 22W; Uout: 30-54Vdc, 210Vdc max.; Iout: 0,20/0,25/0,30/0,35A; Pout: 19W; PF: 0,9C; ta: -20...+50°C; tc: 75°C; built-in</p> <p>CertaDrive 44W 200-350mA 125V DS 230V Uin: 220-240V; Freq: 50/60Hz; Iin: 0,2A; Pin: 48W; Uout: 70-125Vdc, 210Vdc max.; Iout: 0,20/0,25/0,30/0,35A; Pout: 44W; PF: 0,9C; ta: -20...+50°C; tc: 85°C; built-in</p> <p>CertaDrive 65W 200-350mA 185V DS 230V Uin: 220-240V; Freq: 50/60Hz; Iin: 0,3A; Pin: 72W; Uout: 120-185Vdc, 250Vdc max.; Iout: 0,20/0,25/0,30/0,35A; Pout: 65W; PF: 0,9C; ta: -20...+50°C; tc: 85°C; built-in</p> |
| Trademark (if any) | PHILIPS |
| Customer's Testing Facility (CTF) Stage used | |
| Model / Type Ref. | <p>CertaDrive 19W 200-350mA 54V DS 230V</p> <p>CertaDrive 44W 200-350mA 125V DS 230V</p> <p>CertaDrive 65W 200-350mA 185V DS 230V</p> |
| Additional information (if necessary may also be reported on page 2) | <input type="checkbox"/> Additional information on page 2 |

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands



IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

A sample of the product was tested and found
to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-
13:2014/AMD1:2016

National differences:

EU Group Differences

As shown in the Test Report Ref. No. which
forms part of this Certificate

6089142.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands

