Ref. Certif. No.

NL-126822

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Electronic controlgear for LED modules with track adaptor
Name and address of the applicant	Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, Netherlands
Name and address of the manufacturer	Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, Netherlands
Name and address of the factory	
When more than one factory	☐ Additional information on page 2
Ratings and principal characteristics	**Product data** Ratings: Un: 220-240 V; fn: 50/60 Hz; PF: 0,9C; ta: -20…+35 °C; tc: 85 °C; Built-in; SELV (see “General product information” for further ratings)
Trademark / Brand (if any)	PHILIPS, SIGNIFY, XITANIUM or ADVANCE
Customer’s Testing Facility (CTF) Stage used	CTF Stage 3
Model / Type Ref.	Xi pW/a xA yV DS nCz 230V
Additional information	☒ Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016 and IEC 62384:2020 National differences: AU, EU Group Differences, NZ
As shown in the Test Report Ref. No. which forms part of this Certificate	6271341.50(A-B) and 6271341.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-06-15

Signature: May Liu

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional information

Note:
Xi pW/a xA yV DS nCz 230V
Where:
p= the max. output power of the driver, replaced by 1 or 2 digits, in range of 14-26 or 34-42, 1W per step
x= output current range in Amper, any values in range of 0,20-0,65 or 0,70-1,05; 0,05 A per step
y= max. operational output voltage of LED: 40V max;
n= track type: 1 for single phase or 3 for 3 phase
z= enclosure colour of the driver: W – white; B – black; G – gray

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-06-15

Signature: May Liu