Ref. Certif. No.

NL-126701

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Electronic controlgear with track adaptor for LED modules
Name and address of the applicant	Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, Netherlands
Name and address of the manufacturer	Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, Netherlands
Name and address of the factory	
When more than one factory	☒ Additional information on page 2
Ratings and principal characteristics	**Product data** Ratings: Un: 220-240 V; fn: 50/60 Hz; In: 0,25 A; Pn: 50 W; PF: 0,9C; Irated: 0,15-1,05 A; Prated: 42 W; Uoutput: 10-48 Vdc, Uout: 60 Vdc; ta: -20…+35 °C; tc: 80 °C; Built-in with double/reinforce insulation; SELV
Trademark / Brand (if any)	XITANIUM, ADVANCE, PHILIPS or SIGNIFY
Customer's Testing Facility (CTF) Stage used	CTF Stage 3
Model / Type Ref.	Xitanium 42W/a 0.15-1.05A 42V 3CB IA, Xitanium 42W/a 0.15-1.05A 42V 3CG IA, Xitanium 42W/a 0.15-1.05A 42V 3CW IA, Xitanium 42W/a 0.15-1.05A 42V MC 3CB, Xitanium 42W/a 0.15-1.05A 42V MC 3CG and Xitanium 42W/a 0.15-1.05A 42V MC 3CW
Additional information	☐ Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016 and IEC 62384:2020 National differences: AU, EU Group Differences, NZ
As shown in the Test Report Ref. No. which forms part of this Certificate	6271319.50(A-B) and 6271319.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-06-10

Signature: Carol Jwo

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional factory

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-06-10

Signature: Carol Jwo