



## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## **CB TEST CERTIFICATE**

**Product** 

Electronic Controlgear for LED modules

Name and address of the applicant

Signify Netherlands B.V.

High Tech Campus 48, 5656 AE Eindhoven

Netherlands

Name and address of the manufacturer

Signify Netherlands B.V.

High Tech Campus 48, 5656 AE Eindhoven

Netherlands

Name and address of the factory

When more than one factory, please report on page

Ratings and principal characteristics

**Product data** 

Ratings: Pin: 240 W; Uin: 220-240 Vac; Iin: 1,12-0,95 Aac;; Ratings: fn: 50/60 Hz; PF: 0,95;; Ratings: Uin: 186-250 Vdc; Iin: 0,81 Adc max;; Ratings: Output voltage: 125-350 Vdc, Uout: 430 Vdc max. open circuit;; Ratings: lout: 200-1050 mA; Pout: 220 W;; Ratings: ta: -40...+55 °C;

tc(max): 90 °C; Built-in

Trademark / Brand (if any)

Philips Lighting

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Xi FP 220W 0.2-1.0A SNLDAE 230V C170 sXt

Additional information (if necessary may also be reported on page 2)

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016 and IEC 62384:2020

National differences:

**EU Group Differences** 

As shown in the Test Report Ref. No. which forms part of this Certificate

6177027.50 and 6177027.51


This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V. Meander 1051 6825 MJ Arnhem Netherlands

Date: 14 December 2023



Signature: K Xu



NL-102467

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Additional factory

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V. Meander 1051 6825 MJ Arnhem Netherlands

Date: 14 December 2023

Signature: K Xu

