Australia and New Zealand Certificate of Suitability- addendum

Certificate
ULL-102264-A1

Issue date
2026-06-10

Expiration date
2031-06-10

This is to acknowledge that

Signify Netherlands B.V.

High Tech Campus 48, EINDHOVEN 5656 AE
Netherlands

has had

LED DRIVER

[refer following page(s) for models list]

evaluated and meets the requirements of the standard(s)

AS 61347.2.13:2018; AS/NZS 61347.1:2016, Amd 1: 2018, Amd 2: 2025

ANZ Certification Scheme requirements.

Stuart Foster (Certification Officer)

Certification Body:
UL International New Zealand Limited,
54 Tarndale Grove, Albany, Auckland 0632, New Zealand.

Issued for use in Australia and New Zealand only.
All dates are in Year-Month-Day format (YYYY-MM-DD).

JAS-ANZ

www.jasanz.org/register

UL Solutions

© 2026 UL LLC. All rights reserved.

Australia and New Zealand
Certificate of Suitability-addendum

Certificate No: ULL-102264-A1
Original Date of Certification: 2021-07-21
Date of Issue/Revision: 2026-06-10

Trade Name or Trademark: PHILIPS, SIGNIFY, XITANIUM, ADVANCE

Risk Class / NSW Declared Class: EESS OUT OF SCOPE - Non-prescribed / non-declared - Commercial (not certified for residential or household use)

IEC Standard Country Differences: AU and NZ

Certification Marking: The RCM may be applied to the product and all the requirements of all relevant parts of AS/NZS 4417 applicable to the article shall be fulfilled.

Additional Certification Conditions: Product is a component for building in.

Model Details and Additional Information:
Rating :

Xi FP 165W 0.2-0.7A SNLDAE 230V C170 sXt
Uin: 220-240 V~, fn: 50/60 Hz, DC, Iin: 0.82-0.71 A~,
Uin: 186-250 Vdc, Iin: 0.6 Adc max,
Pin: 177 W, PF: 0.95,
Pout: 165 W, Iout: 200-700 mA,
Uout: 100-300 Vdc, Uout(max, open circuit): 340V
tc(max): 90°C, ta: -40…+55 °C

Xi FP 165W 0.3-1.0A SNLDAE 230V C170 sXt
Uin: 220-240 V~, fn: 50/60 Hz, DC, Iin: 0.82-0.71 A~,
Uin: 186-250 Vdc, Iin: 0.6 Adc max,
Pin: 177 W, PF: 0.95,
Pout: 165 W, Iout: 300-1050 mA,
Uout: 80-235 Vdc, Uout(max, open circuit): 280V
tc(max): 90°C, ta: -40…+55 °C

Details of addendum :
- Certificate is renewed.
- Trade names "SIGNIFY", "XITANIUM" and "ADVANCE" added.

© 2026 UL LLC. All rights reserved.
Form-ULID-013925-CoS - ver 2.0