

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Electronic controlgear for LED modules

Name and address of the applicant

Signify Netherlands B.V.
High Tech Campus 48, 5656 AE Eindhoven
Netherlands

Name and address of the manufacturer

Signify Netherlands B.V.
High Tech Campus 48, 5656 AE Eindhoven
Netherlands

Name and address of the factory

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

U_{in}: 220-240 Vac; I_{in}: 0,25 Aac; P_{in}: 53,5 W; Prated: 48 W;
Freq: 50/60 Hz; PF: 0,96; output voltage range: 30-40 Vdc,
U_{out}: 60 Vdc max; I_{rated}: 1,20 A;
ta: -20...+40 °C; tc: 75 °C; Independent; SELV; Class II

Trademark / Brand (if any)



PHILIPS

Customer's Testing Facility (CTF) Stage used

CTF Stage 3

Model / Type Ref.

CertaDrive 48W 1.2A 40V 230V I

Additional information (if necessary may also be reported on page 2)

 Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60598-1:2020, IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016, IEC 62384:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

6156754.50 and 6156754.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
Arnhem, 6825 MJ
Netherlands

Date: 2023-07-12

Signature: Kate Xu

IEC

IECEE

®

™

Ref. Certif. No.

NL-89669

Additional factory

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
Arnhem, 6825 MJ
Netherlands



Date: 2023-07-12

Signature: Kate Xu