

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Controller

Name and address of the applicant

Signify Netherlands B.V.
High Tech Campus 48, 5656 AE Eindhoven, Netherlands

Name and address of the manufacturer

Signify Netherlands B.V.
High Tech Campus 48, 5656 AE Eindhoven, Netherlands

Name and address of the factory

When more than one factory☐ Additional information on page 2

Ratings and principal characteristics

Product data

Ratings: Un: 220-240 Vac; fn: 50/60 Hz; In: 12-20 mA.
ta: -40...+60 °C; tc: 75 °C

Trademark / Brand (if any)

PHILIPS, SIGNIFY, XITANIUM or ADVANCE

Customer's Testing Facility (CTF) Stage used

CTF Stage 3

Model / Type Ref.

Xitanium SR Bridge 9290015464, Xitanium SR Bridge 9290015465,
Xitanium SR Bridge Built-in and Xitanium SR Bridge Independent

Additional information

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-2-11:2001, IEC 61347-2-11:2001/AMD1:2017,
IEC 61347-1:2015 and IEC 61347-1:2015/AMD1:2017

National differences:

AU, EU Group Differences, NZ

As shown in the Test Report Ref. No. which forms part of this Certificate

6271393.50(A-B)

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-06-15


Signature: Caroline Chen