

Australia and New Zealand Certificate of Suitability

Certificate
ULL-104590

Issue date
2026-07-01

Expiration date
2031-07-01



www.jasanz.org/register

This is to acknowledge that

Signify Netherlands B.V.

High Tech Campus 48, EINDHOVEN 5656 AE
Netherlands

has had

Controller

[refer following page(s) for models list]

evaluated and meets the requirements of the standard(s)

**AS/NZS 61347.2.11:2003; AS/NZS
61347.1:2016, Amd 1: 2018, Amd 2: 2025**

ANZ Certification Scheme requirements.



Stuart Foster (Certification Officer)

Certification Body:
UL International New Zealand Limited,
54 Tarndale Grove, Albany, Auckland 0632, New Zealand.

Issued for use in Australia and New Zealand only.
All dates are in Year-Month-Day format (YYYY-MM-DD).

Australia and New Zealand Certificate of Suitability

Certificate No: ULL-104590

Date of Issue/Revision: 2026-07-01

Trade Name or Trademark: PHILIPS, SIGNIFY, XITANIUM, ADVANCE

Risk Class / NSW Declared Class: EESS OUT OF SCOPE - Non-prescribed / non-declared - Commercial (not certified for residential or household use)

IEC Standard Country Differences: AU and NZ

Certification Marking: The RCM may be applied to the product and all the requirements of all relevant parts of AS/NZS 4417 applicable to the article shall be fulfilled.

Additional Certification Conditions: None.

Model Details and Additional Information:

Xitanium SR Bridge Built-in

Un: 220-240 Vac, fn: 50/60 Hz, In: 12-20 mA.

ta: -40...+60 °C, tc: 75 °C

Xitanium SR Bridge Independent

Un: 220-240 Vac, fn: 50/60 Hz, In: 12-20 mA.

ta: -40...+60 °C, tc: 75 °C, NON-IC

For NON-IC LED drivers -

The requirements of EESS General Guidance Notice 20-007 for NON-IC classified LED drivers is applicable.

Refer <https://www.eess.gov.au/news-and-notifications/information-and-advisory-notes> for more information.