Australia and New Zealand Certificate of Suitability

Certificate
ULL-104148

Issue date
2025-09-23

Expiration date
2030-09-23

This is to acknowledge that

Signify Netherlands B.V.

High Tech Campus 48, EINDHOVEN 5656 AE
Netherlands

has had

Lighting Controller/Sensor

[refer following page(s) for models list]

evaluated and meets the requirements of the standard(s)

AS/NZS 61347.1:2016, Amd 1: 2018, Amd 2: 2025; AS/NZS 61347.2.11:2003

ANZ Certification Scheme requirements.

Stuart Foster (Certification Officer)

Certification Body:
UL International New Zealand Limited,
54 Tarndale Grove, Albany, Auckland 0632, New Zealand.

Issued for use in Australia and New Zealand only.
All dates are in Year-Month-Day format (YYYY-MM-DD).

JAS-ANZ

www.jasanz.org/register

UL Solutions

© 2025 UL LLC. All rights reserved.

Australia and New Zealand
Certificate of Suitability

Certificate No: ULL-104148
Date of Issue/Revision: 2025-09-23

Trade Name or Trademark: SIGNIFY, PHILIPS

Risk Class / NSW Declared Class: EESS OUT OF SCOPE - Non-prescribed / non-declared

IEC Standard Country Differences: AU and NZ

Certification Marking: The RCM may be applied to the product and all the requirements of all relevant parts of AS/NZS 4417 applicable to the article shall be fulfilled.

Additional Certification Conditions: None.

Model Details:

Model Name
EasyAir SNM212/w MC
EasyAir SNM212/g MC

Additional Information:
Rating:

Uin: 9.5-22.5 Vdc, Iin: 9.5 mA, Pin: 140 mW,
ta: -30…+55 °C, tc: max 60 °C, IP66, Class II

© 2025 UL LLC. All rights reserved.