

CERTIFICATE

Issued to:
Applicant:
Signify Netherlands B.V.
High Tech Campus 48
5656 AE Eindhoven, Netherlands

Licensee:
Signify Netherlands B.V.
High Tech Campus 48
5656 AE Eindhoven, Netherlands

Product : Electronic Controlgear for LED modules
Trade name(s) : PHILIPS
Type(s)/model(s) : Xitanium 100W 350-500mA 200V DS 230V,
Xitanium 100W 350-500mA 200V DS 230V AW,
Xitanium 100W 350-500mA 200V DS 230V EL,
Xitanium 150W 400-700mA 215V DS 230V,
Xitanium 150W 400-700mA 215V DS 230V EL,
Xitanium 80W 400-550mA 200V DS 230V and
Xitanium 90W 200-350mA 256V DS 230V EL

The product and any acceptable variation thereof as specified in the Annex to this certificate and the documents referred to therein.

DEKRA hereby declares that the above-mentioned product has been certified based on:

- a type test according to EN 61347-2-13:2014, EN 61347-2-13:2014/A1:2017, EN 61347-1:2015, EN 61347-1:2015/A1:2021 and EN IEC 62384:2020
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 947556


DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the ENEC certification agreement.


This certificate is issued on 13 March 2025 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 31-137437 REV.3

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



Kate Xu
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Electronic Controlgear for LED modules
Trade name(s)	: PHILIPS
Type(s)/model(s)	: Xitanium 100W 350-500mA 200V DS 230V, Xitanium 100W 350-500mA 200V DS 230V AW, Xitanium 100W 350-500mA 200V DS 230V EL, Xitanium 150W 400-700mA 215V DS 230V, Xitanium 150W 400-700mA 215V DS 230V EL, Xitanium 80W 400-550mA 200V DS 230V and Xitanium 90W 200-350mA 256V DS 230V EL
Power factor (PF)	: 0,9C
Ambient temperature range (ta)	: -25...+50 °C
Max case temperature (tc)	: 85 °C
Description	: Built-in; non-isolating

Product data – type Xitanium 100W 350-500mA 200V DS 230V

Input voltage	: 220-240 Vac
Rated frequency	: 50/60 Hz
Input current	: 0,5 Aac
Input power	: 104 W
Output voltage	: 100-200 Vdc
Max working voltage (Uout)	: 250 V
Output current	: 0,35 / 0,4 / 0,45 / 0,5 A
Output power	: 100 W

Product data – type Xitanium 100W 350-500mA 200V DS 230V AW and Xitanium 100W 350-500mA 200V DS 230V EL

Input voltage	: 220-240 Vac or 186-250 Vdc
Rated frequency	: 50/60 Hz or DC
Input current	: 0,5 Aac or 0,38-0,55 Adc
Input power	: 104 W
Output voltage	: 80-200 Vdc
Max working voltage (Uout)	: 250 V
Output current	: 0,35 / 0,4 / 0,45 / 0,5 A
Output power	: 100 W

Product data – type Xitanium 150W 400-700mA 215V DS 230V

Input voltage	: 220-240 Vac
Rated frequency	: 50/60 Hz
Input current	: 0,75 Aac
Input power	: 156 W
Output voltage	: 140-215 Vdc
Max working voltage (Uout)	: 300 V
Output current	: 0,4 / 0,5 / 0,6 / 0,7 A
Output power	: 150 W

Product data – type Xitanium 150W 400-700mA 215V DS 230V EL

Input voltage	: 220-240 Vac or 186-250 Vdc
Rated frequency	: 50/60 Hz or DC
Input current	: 0,75 Aac or 0,6-0,85 Adc
Input power	: 156 W
Output voltage	: 140-215 Vdc

Max working voltage (Uout) : 300 V
Output current : 0,4 / 0,5 / 0,6 / 0,7 A
Output power : 150 W

Product data – type Xitanium 80W 400-550mA 200V DS 230V

Input voltage : 220-240 Vac
Rated frequency : 50/60 Hz
Input current : 0,39 Aac
Input power : 84 W
Output voltage : 80-200 Vdc
Max working voltage (Uout) : 250 V
Output current : 0,4 / 0,45 / 0,5 / 0,55 A
Output power : 80 W

Product data – type Xitanium 90W 200-350mA 256V DS 230V EL

Input voltage : 220-240 Vac or 186-250 Vdc
Rated frequency : 50/60 Hz or DC
Input current : 0,43 Aac or 0,34-0,49 Adc
Input power : 94 W
Output voltage : 150-256 Vdc
Max working voltage (Uout) : 300 V
Output current : 0,2 / 0,25 / 0,3 / 0,35 A
Output power : 90 W

TESTS**Test requirements**

EN 61347-2-13:2014
EN 61347-2-13:2014/A1:2017
EN 61347-1:2015
EN 61347-1:2015/A1:2021
EN IEC 62384:2020

Test result

The test results are documented in DEKRA test file 621906200.

Additional information

This certificate replaces certificate No. 31-137437 REV.2 which we hereby declare invalid.

The list of components is laid down in test report 6219062.50A.

Conclusion

The examination has confirmed that all requirements were met.

Factory location

The factory location is registered with the number 41289.