Ref. Certif. No.

NL-126299

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Electronic Controlgear for LED modules
Name and address of the applicant	Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, Netherlands
Name and address of the manufacturer	Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, Netherlands
Name and address of the factory	
When more than one factory	☐ Additional information on page 2
Ratings and principal characteristics	**Product data** Ratings: Xitanium 75W 0.7-2.0A 54V S 230V G2 Xitanium 75W 0.7-2.0A 54V 230V G2 Un: 220-240 Vac; In: 0,38 Aac; fn: 50/60 Hz or DC; PF: 0,9C; Un: 186-250 Vdc; In: 0,46-0,34 Adc; Pn: 85 W; Output voltage: 24-54 Vdc; Uout: 60 V max; Irated: 0,7-2,0 A; Prated: 75 W; tc: 75 °C; ta: -25…+50 °C; Built-in; EL; SELV Xitanium 36W 0.3-1.0A 54V S 230V G2 Xitanium 36W 0.3-1.0A 54V 230V G2 Un: 220-240 Vac; In: 0,2 Aac; fn: 50/60 Hz or DC; PF: 0,9C; Un: 186-250 Vdc; In: 0,24-0,17 Adc; Pn: 41 W; Output voltage: 24-54 Vdc; Uout: 60 V max; Irated: 0,3-1,0 A; Prated: 36 W; tc: 75 °C; ta: -25…+50 °C; Built-in; EL; SELV
Trademark / Brand (if any)	PHILIPS, SIGNIFY, ADVANCE or XITANIUM
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	Xitanium 36W 0.3-1.0A 54V 230V G2, Xitanium 36W 0.3-1.0A 54V S 230V G2, Xitanium 75W 0.7-2.0A 54V 230V G2 and Xitanium 75W 0.7-2.0A 54V S 230V G2
Additional information	☐ Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016 and IEC 62384:2020

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-06-01

Signature: Carol Jwo

Ref. Certif. No.

NL-126299

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

National differences:
AU, EU Group Differences, NZ

As shown in the Test Report Ref. No. which forms part of this Certificate

6271208.50(A-B) and 6271208.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-06-01

Signature: Carol Jwo