

Certificate of Suitability

Global-Mark Pty. Ltd., certify the electrical equipment described hereunder complies with standards listed herein and notifies the certificate holder to affix the Regulatory Compliance Mark (RCM) mark on the product of the same type provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled. In placing the RCM mark on the product, the Responsible Supplier makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. This Certificate meets the requirements of a Recognised External Certification Scheme (RECS).

CERTIFICATION AND CERTIFICATE HOLDER DETAILS

Company Name	Signify Netherlands B.V	Other Name	
Address	High Tech Campus 48 Eindhoven - 5656 AE Netherlands		
Client ID	105985	Global-Mark File Number:	105985-118
Certification Number	GMA-520633	Revision Number	00
Certificate Standard(s)	AS 61347.2.13:2018 & AS/NZS 61347.1:2016 + A1 Lamp Control Gear - Part 2-13: Particular Requirements For D.C Or A.C Supplied Electronic Control Gear For Led Modules.		
Type of Certification	Electrical Safety Product	Scheme	Global-Mark Electrical Product Safety Certification Scheme
			System 1 Approval

CERTIFICATE DATES

Certificate Issue Date	23/10/2024
Certificate Last Update Date	
Certification Expiry Date	23/10/2029

This certification remains valid until the above-mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jasanz.org/register for verification.



Certification Manager



Certificate of Suitability

CERTIFIED ELECTRICAL EQUIPMENT				
Declared Article	Product Description	Trade Name	Model Number	Rating
Non declared	Electronic Controlgear for LED modules	PHILIPS	Xitanium 75W 0.7-2.0A 54V S 230V G2	Un: 220-240 Vac; In: 0,38 Aac; fn: 50/60 Hz or DC; PF: 0,9C; Un: 186-250 Vdc; In: 0,46-0,34 Adc; Pn: 85 W; Output voltage: 24-54 Vdc; Uout: 60 V max; Irated: 0,7-2,0 A; Prated: 75 W; tc: 75 °C; ta: -25...+50 °C; Built-in; EL; SELV
Non declared	Electronic Controlgear for LED modules	PHILIPS	Xitanium 36W 0.3-1.0A 54V S 230V G2	Un: 220-240 Vac; In: 0,2 Aac; fn: 50/60 Hz or DC; PF: 0,9C; Un: 186-250 Vdc; In: 0,24-0,17 Adc; Pn: 41 W; Output voltage: 24-54 Vdc; Uout: 60 V max; Irated: 0,3-1,0 A; Prated: 36 W; tc: 75 °C; ta: -25...+50 °C; Built-in; EL; SELV
Non declared	Electronic Controlgear for LED modules	PHILIPS	Xitanium 75W 0.7-2.0A 54V S 230V G2	Un: 220-240 Vac; In: 0,38 Aac; fn: 50/60 Hz or DC; PF: 0,9C; Un: 186-250 Vdc; In: 0,46-0,34 Adc; Pn: 85 W; Output voltage: 24-54 Vdc; Uout: 60 V max; Irated: 0,7-2,0 A; Prated: 75 W; tc: 75 °C; ta: -25...+50 °C; Built-in; EL; SELV
Non declared	Electronic Controlgear for LED modules	PHILIPS	Xitanium 36W 0.3-1.0A 54V S 230V G2	Un: 220-240 Vac; In: 0,2 Aac; fn: 50/60 Hz or DC; PF: 0,9C; Un: 186-250 Vdc; In: 0,24-0,17 Adc; Pn: 41 W; Output voltage: 24-54 Vdc; Uout: 60 V max; Irated: 0,3-1,0 A; Prated: 36 W; tc: 75 °C; ta: -25...+50 °C; Built-in; EL; SELV

RELEVANT TRADEMARK (S)

COMMENTS OR CONDITIONS ON THE CERTIFICATION

This certification remains valid until the above-mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jasanz.org/register for verification.



Certification Manager



Certificate of Suitability

End of document



This certification remains valid until the above-mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jasanz.org/register for verification.



Certification Manager

