Ref. Certif. No.

NL-112094/M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Electronic Controlgear for LED modules
Name and address of the applicant	Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, Netherlands
Name and address of the manufacturer	Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, Netherlands
Name and address of the factory	
When more than one factory	☐ Additional information on page 2
Ratings and principal characteristics	**Product data** Ratings: Xitanium 65W 200-350mA 185V DS 230V CCT Uin: 220-240 Vac; Freq: 50/60 Hz; PF: 0,9C; Iin: 0,32 Aac; Pin: 70 W; Irated: 0,2 A/ 0,25 A/ 0,3 A/ 0,35 A; Prated: 65 W; Uoutput: 120-185 Vdc; Uout: 250 Vdc; ta: -25…+50°C; tc: 85°C; built-in Xitanium 44W 200-350mA 125V DS 230V CCT Uin: 220-240 Vac; Freq: 50/60 Hz; PF: 0,9C; Iin: 0,23 Aac; Pin: 48 W; Irated: 0,2 A/ 0,25 A/ 0,3 A/ 0,35 A; Prated: 44 W; Uoutput: 70-125 Vdc; Uout: 220 Vdc; ta: -25…+50°C; tc: 85°C; built-in Xitanium 19W 200-350mA 54V DS 230V CCT Uin: 220-240 Vac; Freq: 50/60 Hz; PF: 0,9C; Iin: 0,11 Aac; Pin: 22 W; Irated: 0,2 A/ 0,25 A/ 0,3 A/ 0,35 A; Prated: 19 W; Uoutput: 30-54 Vdc; Uout: 220 Vdc; ta: -25…+50°C; tc: 75°C; built-in
Trademark / Brand (if any)	SIGNIFY, XITANIUM, ADVANCE or PHILIPS
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	Xitanium 19W 200-350mA 54V DS 230V CCT, Xitanium 44W 200-350mA 125V DS 230V CCT and Xitanium 65W 200-350mA 185V DS 230V CCT
Additional information	☐ Additional information on page 2

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-08-21

Signature: Kate Xu

Ref. Certif. No.

NL-112094/M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

A sample of the product was tested and found to be in conformity with	IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016 and IEC 62384:2020 National differences: AU, EU Group Differences, NZ Comments: This CB test certificate replaces CB test certificate NL-112094. Dated on 2024-11-05 due to technical modifications.
As shown in the Test Report Ref. No. which forms part of this Certificate	6284001.50(A-B) and 6284001.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-08-21

Signature: Kate Xu