Australia and New Zealand Certificate of Suitability- addendum

Certificate
ULL-103719-A1

Issue date
2026-06-03

Expiration date
2031-06-03

This is to acknowledge that

Signify Netherlands B.V.

High Tech Campus 48, EINDHOVEN 5656 AE
Netherlands

has had

Electronic Controlgear for LED modules

[refer following page(s) for models list]

evaluated and meets the requirements of the standard(s)

AS 61347.2.13:2018; AS/NZS 61347.1:2016, Amd 1: 2018, Amd 2: 2025

ANZ Certification Scheme requirements.

Stuart Foster (Certification Officer)

Certification Body:
UL International New Zealand Limited,
54 Tarndale Grove, Albany, Auckland 0632, New Zealand.

Issued for use in Australia and New Zealand only.
All dates are in Year-Month-Day format (YYYY-MM-DD).

JAS-ANZ

www.jasanz.org/register

© 2026 UL LLC. All rights reserved.

Australia and New Zealand
Certificate of Suitability-addendum

Certificate No: ULL-103719-A1
Original Date of Certification: 2025-01-10
Date of Issue/Revision: 2026-06-03

Trade Name or Trademark: PHILIPS, SIGNIFY, XITANIUM, ADVANCE

Risk Class / NSW Declared Class: EESS OUT OF SCOPE - Non-prescribed / non-declared

IEC Standard Country Differences: AU and NZ

Certification Marking: The RCM may be applied to the product and all the requirements of all relevant parts of AS/NZS 4417 applicable to the article shall be fulfilled.

Additional Certification Conditions: Product is a component for building in.

Model Details and Additional Information:
Xitanium 42W 0.7-1.05A 40V HE 3CW 230V
Un: 220-240 Vac, fn: 50/60 Hz, PF: 0.9C.
In: 0.14/0.15/0.16/0.17/0.18/0.19/0.20/0.21 Aac,
Pn: 30/32/34/36/39/41/43/45 W,
Irated: 0.70/0.75/0.80/0.85/0.90/0.95/1.00/1.05 Adc,
Prated: 28/30/32/34/36/38/40/42 W,
Uoutput: 25-40 Vdc, Uout: 60 Vdc max,
ta: -20…+35 °C, tc: 80 °C, Built-in, SELV.

Xitanium 42W 0.7-1.05A 40V HE 3CB 230V
Un: 220-240 Vac, fn: 50/60 Hz, PF: 0.9C,
In: 0.14/0.15/0.16/0.17/0.18/0.19/0.20/0.21 Aac,
Pn: 30/32/34/36/39/41/43/45 W,
Irated: 0.70/0.75/0.80/0.85/0.90/0.95/1.00/1.05 Adc,
Prated: 28/30/32/34/36/38/40/42 W,
Uoutput: 25-40 Vdc, Uout: 60 Vdc max,
ta: -20…+35 °C, tc: 80 °C, Built-in, SELV.

Xitanium 42W 0.7-1.05A 40V HE 3CG 230V
Un: 220-240 Vac, fn: 50/60 Hz, PF: 0.9C,
In: 0.14/0.15/0.16/0.17/0.18/0.19/0.20/0.21 Aac,
Pn: 30/32/34/36/39/41/43/45 W,
Irated: 0.70/0.75/0.80/0.85/0.90/0.95/1.00/1.05 Adc,
Prated: 28/30/32/34/36/38/40/42 W,
Uoutput: 25-40 Vdc, Uout: 60 Vdc max,
ta: -20…+35 °C, tc: 80 °C, Built-in, SELV.

Xitanium 28W 0.35-0.7A 40V HE 3CW 230V
Un: 220-240 Vac, fn: 50/60 Hz, PF: 0.85C/0.9C,
In: 0.07/0.08/0.09/0.10/0.11/0.12/0.13/0.14 Aac,
Pn: 16/18/20/22/24/26/28/30 W,
Irated: 0.35/0.40/0.45/0.50/0.55/0.60/0.65/0.70 Adc,
Prated: 14/16/18/20/22/24/26/28 W,
Uoutput: 30-40 Vdc, Uout: 60 Vdc max,
ta: -20…+35 °C, tc: 80 °C, Built-in, SELV.

© 2026 UL LLC. All rights reserved.

Australia and New Zealand
Certificate of Suitability-addendum

Certificate No: ULL-103719-A1
Original Date of Certification: 2025-01-10
Date of Issue/Revision: 2026-06-03

Xitanium 28W 0.35-0.7A 40V HE 3CB 230V
Un: 220-240 Vac, fn: 50/60 Hz, PF: 0.85C/0.9C,
In: 0.07/0.08/0.09/0.10/0.11/0.12/0.13/0.14 Aac,
Pn: 16/18/20/22/24/26/28/30 W,
Irated: 0.35/0.40/0.45/0.50/0.55/0.60/0.65/0.70 Adc,
Prated: 14/16/18/20/22/24/26/28 W,
Uoutput: 30-40 Vdc, Uout: 60 Vdc max,
ta: -20…+35 °C, tc: 80 °C, Built-in, SELV.

Xitanium 28W 0.35-0.7A 40V HE 3CG 230V
Un: 220-240 Vac, fn: 50/60 Hz, PF: 0.85C/0.9C,
In: 0.07/0.08/0.09/0.10/0.11/0.12/0.13/0.14 Aac,
Pn: 16/18/20/22/24/26/28/30 W,
Irated: 0.35/0.40/0.45/0.50/0.55/0.60/0.65/0.70 Adc,
Prated: 14/16/18/20/22/24/26/28 W,
Uoutput: 30-40 Vdc, Uout: 60 Vdc max,
ta: -20…+35 °C, tc: 80 °C, Built-in, SELV.

Xitanium 12W 0.15-0.3A 40V HE 3CW 230V
Un: 220-240 Vac, fn: 50/60 Hz, PF: 0.85C/0.9C,
In: 0.04/0.05/0.06/0.07 Aac, Pn: 7/9/12/14 W,
Irated: 0.15/0.20/0.25/0.30 Adc, Prated: 6/8/10/12 W,
Uoutput: 30-40 Vdc, Uout: 60 Vdc max,
ta: -20…+35 °C, tc: 80 °C, Built-in, SELV.

Xitanium 12W 0.15-0.3A 40V HE 3CB 230V
Un: 220-240 Vac, fn: 50/60 Hz, PF: 0.85C/0.9C,
In: 0.04/0.05/0.06/0.07 Aac, Pn: 7/9/12/14 W,
Irated: 0.15/0.20/0.25/0.30 Adc, Prated: 6/8/10/12 W,
Uoutput: 30-40 Vdc, Uout: 60 Vdc max,
ta: -20…+35 °C, tc: 80 °C, Built-in, SELV.

Xitanium 12W 0.15-0.3A 40V HE 3CG 230V
Un: 220-240 Vac, fn: 50/60 Hz, PF: 0.85C/0.9C,
In: 0.04/0.05/0.06/0.07 Aac, Pn: 7/9/12/14 W,
Irated: 0.15/0.20/0.25/0.30 Adc, Prated: 6/8/10/12 W,
Uoutput: 30-40 Vdc, Uout: 60 Vdc max,
ta: -20…+35 °C, tc: 80 °C, Built-in, SELV.

Details of addendum:
- Certificate is renewed.
- Trade name "XITANIUM" and "ADVANCE" added.

© 2026 UL LLC. All rights reserved.
Form-ULID-013925-CoS - ver 2.0