Ref. Certif. No.

SG PSB-LE-07724

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Power supply
Name and address of the applicant	**Signify (China) Investment Co., Ltd.** Building No. 9, Lane 888, Tianlin Road Minhang District 200233 Shanghai PEOPLE'S REPUBLIC OF CHINA
Name and address of the manufacturer	Signify (China) Investment Co., Ltd. Building No. 9, Lane 888, Tianlin Road, Minhang District, 200233 Shanghai, PEOPLE'S REPUBLIC OF CHINA
Name and address of the factory	
Ratings and principal characteristics	Rated Voltage: 220-240V~ Rated Frequency: 50/60Hz Rated input current: See model list Rated output: See model list Protection against Electric Shock: Class II; SELV Degree of Protection: IP20 Method of Installation: Independent Type of Output: Constant voltage ta, tc: See model list
Trademark / Brand (if any)	PHILIPS, SIGNIFY, XITANIUM, ADVANCE
Model/type Ref.	Xi LED Transformer 100W TD 48VDC, Xi LED Transformer 150W TD 48VDC, Xi LED Transformer 250W TD 48VDC, Xi LED Transformer 100W 48VDC, Xi LED Transformer 150W 48VDC, Xi LED Transformer 250W 48VDC, Xi LED Transformer 60W TD 48VDC
A sample of the product was tested and found to be in conformity with	IEC 61347-1:2024 IEC 61347-2-13:2024
as shown in the Test Report Ref. No. which forms part of this certificate	085-260153402-000

This CB Test Certificate is issued by the National Certification Body

CBS 102213 0366 Rev. 01

Date, 2026-10-23

(Shaochang Liu)

TÜV SÜD PSB Pte Ltd 15 International Business Park TÜV SÜD @ IBP Singapore 609937

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Model list:

Item	Model	Rated input current (A)	PF	Rated output voltage (VDC)	Rated output current (mA)	Rated output power (W)	Max. Uout (VDC)	ta/tc (°C)
1	Xi LED Transformer 100W TD 48VDC	0.58	0.90C	48	625-2083	30-100	50	-25 to 45/85
2	Xi LED Transformer 150W TD 48VDC	0.87	0.90C	48	937-3125	45-150	50	-25 to 45/90
3	Xi LED Transformer 250W TD 48VDC	1.4	0.90C	48	1560-5210	75-250	50	-25 to 45/90
4	Xi LED Transformer 100W 48VDC	0.6	0.95	48	0-2100	0-100.8	50	-25 to 45/90
5	Xi LED Transformer 150W 48VDC	0.9	0.95	48	0-3125	0-150	50	-25 to 45/90
6	Xi LED Transformer 250W 48VDC	1.5	0.95	48	0-5210	0-250	50	-25 to 45/90
7	Xi LED Transformer 60W TD 48VDC	0.31	0.90C	48	375-1250	18-60	50	-20 to 50/85

This CB Test Certificate is issued by the National Certification Body

CBS 102213 0366 Rev. 01

Date, 2026-10-23

(Shaochang Liu)

TÜV SÜD PSB Pte Ltd 15 International Business Park TÜV SÜD @ IBP Singapore 609937