



Ref. Certif. No.

NL-100605

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Electric source for safety services (ESSS) supplied electronic controlgear for emergency lighting (self-contained)

Name and address of the applicant

Signify Netherlands B.V.
High Tech Campus 48, 5656 AE Eindhoven
Netherlands

Name and address of the manufacturer

Signify Netherlands B.V.
High Tech Campus 48, 5656 AE Eindhoven
Netherlands

Name and address of the factory

Fideltronik Poland Sp. z o.o.
Ul Beniowskiego 1, 34-200 Sucha Beskidzka
Poland*When more than one factory, please report on page 2*

Ratings and principal characteristics

☐ Additional information on page 2

Product data – type TrustSight Basic 45-300V LFP+, TrustSight DALI 45-300V LFP+ and TrustSight PRO 45-300V LFP+
Ratings: Un: 220...240 V; In: 30 mA; Pn: 3-6 W; fn: 50/60 Hz; PF: 0,4-0,8C;
U-OUT: 330 V; P-OUT: 3-5 W; I-OUT: 10-120 mA;
ta: -20...+55 °C; tc: +75 °C;

Product data – type TrustSight Basic 45-300V NiMH+, TrustSight DALI 45-300V NiMH+ and TrustSight PRO 45-300V NiMH+
Ratings: Un: 220...240 V; In: 30 mA; Pn: 3-5 W; fn: 50/60 Hz; PF: 0,4-0,7C;
U-OUT: 330 V; P-OUT: 3-5 W; I-OUT: 10-120 mA;
ta: -20...+55 °C; tc: +75 °C;

Trademark / Brand (if any)

PHILIPS

Customer's Testing Facility (CTF) Stage used

CTF Stage 3

Model / Type Ref.

TrustSight Basic 45-300V LFP+, TrustSight Basic 45-300V NiMH+,
TrustSight DALI 45-300V LFP+, TrustSight DALI 45-300V NiMH+,
TrustSight PRO 45-300V LFP+ and TrustSight PRO 45-300V NiMH+

Additional information (if necessary may also be reported on page 2)

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-7:2011,
IEC 61347-2-7:2011/AMD1:2017, IEC 61347-2-7:2011/AMD2:2021,
IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016, IEC 62384:2020
and IEC 60598-1:2020

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 27 September 2023

Signature: R Zhou



Ref. Certif. No.

NL-100605

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

As shown in the Test Report Ref. No.
which forms part of this Certificate

National differences:
EU Group Differences

6163540.53 and 6163540.54 and 6163540.55

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands



Date: 27 September 2023

Signature: R Zhou