

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Controller

Name and address of the applicant

Signify Netherlands B.V.  
High Tech Campus 48, 5656 AE Eindhoven  
Netherlands

Name and address of the manufacturer

Signify Netherlands B.V.  
High Tech Campus 48, 5656 AE Eindhoven  
Netherlands

Name and address of the factory

*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

Un: 220-240 Vac; fn: 50/60 Hz; In: 12-20 mA.  
ta: -40...+60 °C; tc: 75 °C

Trademark (if any)

  
PHILIPS

Customer's Testing Facility (CTF) Stage used

CTF Stage 3

Model / Type Ref.

Xitanium SR Bridge 9290015464  
Xitanium SR Bridge 9290015465  
Xitanium SR Bridge Built-in  
Xitanium SR Bridge Independent

Additional information (if necessary may also be reported on page 2)

This certificate replaces NL- 48058 dated on 2017-08-04 due to technical modifications.

☐ [Additional information on page 2](#)

A sample of the product was tested and found to be in conformity with

IEC 60598-1:2014, IEC 60598-1:2014/AMD1:2017, IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-11:2001, IEC 61347-2-11:2001/AMD1:2017

National differences:

EU Group Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

6134714.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051  
Arnhem, 6825 MJ  
Netherlands



Date: 2022-07-28

Signature: Kate Xu