

# CERTIFICATE

Issued to:  
Applicant:  
**Signify Netherlands B.V.**  
**High Tech Campus 48**  
**5656 AE Eindhoven, Netherlands**

Licensee:  
**Signify Netherlands B.V.**  
**High Tech Campus 48**  
**5656 AE Eindhoven, Netherlands**

Product : Lighting Controller  
Trade name(s) : PHILIPS or SIGNIFY  
Type(s)/model(s) : MCtoDALI Bridge

The product and any acceptable variation thereof as specified in the Annex to this certificate and the documents referred to therein.

DEKRA hereby declares that the above-mentioned product has been certified based on:

- a type test according to EN IEC 61347-2-11:2024 and EN IEC 61347-1:2024
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 947556


DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the ENEC certification agreement.

This certificate is issued on 28 January 2026 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 31-170860

DEKRA Certification B.V.



B.T.M. Holtus  
Managing Director



Kreny Lin  
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE  
DUTCH ACCREDITATION  
COUNCIL



**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

Product	: Lighting Controller
Trade name(s)	: PHILIPS or SIGNIFY
Type(s)/model(s)	: MCtoDALI Bridge
Rated input voltage	: 220-240 Vac
Rated frequency	: 50/60 Hz
Rated input current	: 10 mA
Rated input power	: 250 mW
Mac. case temperature (tc)	: 75 °C
Ambient temperature range(ta)	: -30...+65 °C
Description	: Independent; Class II

**TESTS****Test requirements**

EN IEC 61347-2-11:2024  
EN IEC 61347-1:2024

**Test result**

The test results are documented in DEKRA test file 6251853.50.

**Additional information**

There is the basic insulation between Dali circuits & mains input.  
The tests were performed by the manufacturer under the conditions of the agreement concerning the manufacturer's right to conduct type tests for the ENEC certification system under supervision of DEKRA (CTF Stage 3).

The list of components is laid down in test report 6251853.50.

**Conclusion**

The examination has confirmed that all requirements were met.

**Factory locations**

The factory locations are registered with the numbers 674666 and 305810.