Sync Wall LED

Installation Instructions

ID_7408_Sync_Wall_LED

Standalone or continuous run configurations




System Overview

mechanical details before beginning installation.

These instructions review how to install Sync wall mount fixtures. Sync 4 ft and 8 ft modules can be installed as individual standalone units, or they can be joined together to create continuous rows. The graphic below shows the components required to install a typical row of Sync wall mount fixtures.

IMPORTANT: Read all instructions including fixture wiring AND





Sync Joint Kits 2x 1/2" plug

2x #10-24 lock nut 2x #10-24 x 9/16" bolt 1x gasket

1x gasket

Sync End Kits 1x endcap 2x 1/2" plug

2x 1/2" plug

2x 5/32" self threading nuts

TOOLS REQUIRED: Stubby Phillips screwdriver, 3/8 " nut driver.

Sync Power Kits

1x j-box cover 1x strain relief

Module Lengths


Sync wall mount systems come in 4ft and 8ft modules. Overall module lengths are shown to the right. Module lengths do not include endcaps.



Indicates overall length of fixture (excluding endcaps)

Endcaps

Add two endcaps to the overall length of each row.



Mount Spacing

- Mounts variable within 2" 5" of end or joint. On 8ft module, additional mount to be located within 2" - 5" of center of module.
- Maximum distance between mounts is 48". Note: Fixture is flush with wall.

Row Configurations

The tables below indicate how 4ft and 8ft modules can be combined to create continuous rows of various lengths.

Nominal row length	4ft module	8ft module
4'	1x	
8'		1x
12'	1x	1x
16'		2x
20'	1x	2x
24'		3x
28'	1x	3x
32'		4x

Sync Wall LED

Installation Instructions

ID 7408 Sync Wall LED


Standalone or continuous run configurations



IMPORTANT: Read all instructions at least once prior to beginning installation.

All mount brackets must be secured towall structure (eg. studs or cross-braces).


This equipment has been tested and found to comply with the limits for a Class A digital device, pursuant to part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interreference when the equipment is operated in a commercial environment. This equipment generates, uses, and can radiate radio frequency energy and, if not installed and used in accordance with the instruction manual, may cause harmful interference to radio communications. Operation of this equipment in a residential area is likely to cause harmful interference in which case the user will be required to correct the interference at his own expense.



Determine power feed location and install 2"x4" utility box (supplied by others) parallel with fixture. Complete connections at utility box with supplied power cord. Attach cover bracket using supplied hardware. Punch power access hole in supplied cover, feed power cord through and attach strain relief on wall side. Attach cover using supplied painted hardware.

strain relief

NOTE: Bottom of utility box should be in line with bottom of wall brackets.




Determine fixture mounting location and secure wall brackets to structure using appropriate fasteners (two per bracket, supplied by others). 4ft fixtures: Require two bracket assemblies; 8ft fixtures: Require three bracket assemblies. Brackets must be installed a maximum of 5" from end of fixture (on 8ft fixture, the third bracket can be 5" of ether side of inrow crossplate).

NOTE: Mounted fixture(s) will sit approximately 4" above top edge of bracket assembly.

Unpack / Prepare fixtures


Arrange boxed fixtures on floor in specified locations: remove fixtures from boxes: remove plastic from fixtures. Cap all unnecessary power feed holes at back of fixture(s) using supplied 1/2" plugs.

Remove Top Reflector




Shift top reflector to the left and then remove the reflector.

Remove Front Reflector




Remove the screws holding the front reflector and then remove the front reflector.

Raise Fixture and Engage on Wall Brackets



With 2 people, raise fixture into position and engage it on hooks located on top of wall brackets, then rotate it down into position. Secure bracket using supplied hardware.

POWER LOCATIONS: Prior to engaging fixture in mounting brackets, feed installed power cord through the access hole at back of the fixture.



To access wiring, remove screw from top pan and lift pan off. Apply strain relief to power cord.

NOTE: Care should be taken when lifting up top reflector to avoid disconnecting internal wiring.

ATTENTION: Install in accordance with national and local building and electrical codes.

Page 2

Sync Wall LED

wirenuts (supplied

by others)

Installation Instructions


ID_7408_Sync_Wall_LED

Standalone or continuous run configurations




Complete electrical connections strain relief

Complete electrical connections using wire nuts (supplied by others). Re-install pan and hardware removed in STEP 6.




LEVEL: Using 5/16" hex nut driver, level fixture by adjusting the tilt screw.

SECURE: Secure fixture to wall bracket assemblies by tightening the lock screw.



With two people, raise second fixture and engage on mounting brackets (see STEP 4). At joint, remember to insert black gasket.




Complete in-row electrical connections.

NON-POWER LOCATIONS: Use supplied guick-wire connectors. Tuck wires into wire cavity.

POWER LOCATIONS: Remove installed guick-wire connectors and complete electrical connections using wire nuts (supplied by others). Tuck wires into wiring cavity.

NOTE: Use smallest appropriate wire nuts.


Level and secure additional fixture



Level second fixture by adjusting the tiltscrew (see step 8). Slide second fixture flush against first fixture and secure joint using supplied nut and bolt hardware (requires 3/8" nut drivers). Secure fixture to wall brackets by tightening the lock screw at each bracket location (see step 8).

Repeat steps 8-10 for each additional fixture(s) in row.


Install Endcaps



Attach endcap to first and last module in each row using supplied hardware.


IMPORTANT: Do not over-tighten endcap fasteners. Ledalite recommends tightening fasteners by hand. When nut is flush with crossplate, turn an additional 1/4 turn.

Re-install Front Reflector



Re-install front reflector using short (stubby) screwdriver.

Install Light Guide and Re-install Top Reflector



Identify smooth side of the Light Guide and ensure it is installed smooth side DOWN.

Install Light Guide panel into LED fixture after joining and wiring is complete. Ensure panel isseated correctly as shown above.

Final Step: Install the top reflector and shift into place.

ATTENTION: Install in accordance with national and local building and electrical codes.

Page 3